

Memorandum

Ref: M13-1-V 3

To: Whom it may concern
From: Pierre El Khoury, Director of the Lebanese Center for Energy Conservation
Date: February 27, 2018
Subject: **Photovoltaic Battery Sizing Requirements for residential use**
Reference: Contract signed between BDL and LCEC "Technical Support Consultancy Services Agreement in Energy Efficiency and Renewable Energy"

The Technical Support Unit to the Central Bank of Lebanon at the Lebanese Center for Energy Conservation (LCEC) sets the minimum requirements for Residential Photovoltaic systems battery sizing to ensure reliable and proper implementation.

(1) Storage capacity shall not exceed 7800Wh per kW_{peak} (at C10).

Companies are hereby required to abide by these recommendations to meet the minimum requirements set by the LCEC, in order to be eligible for NEEREA green loans.

LCEC remains ready to answer any inquiries or questions via email at energy@lcec.org.lb, or by phone at 01 565108.


Pierre El Khoury
Director, LCEC

efficient resources, sustainable achievements

كفاءة في الموارد، إستدامة في الإنجازات